

VOC Content Test Certificate

Thursday April 19th, 2012

Manufacturer: Laticrete Pty Ltd (29 Telford St, Virginia, QLD 4014)

Sample Description: Laticrete 335 Premium Flexible Adhesive

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Laticrete 335 Premium Flexible Adhesive</p>
<p>Any solvent based coating whose purpose is not covered in table</p> <p>200 grams per Litre as VOC content per material</p>	<p>4 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120411